



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 5/12/09

Code **31-09R**

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

| | | |
|---|---|-------------------------|
| Code Title International Residential Code | | Edition 2009 |
| Section number and title R311.2 Egress Door - revised | | Page 62 |
| Proponent Carolyn Schleif | Title President, Nightingale Designs, Inc. | |
| Address 10517 Hyde Park, Carmel, IN 46032 | | Phone (317) 580-0540 |
| PROPOSED CODE CHANGE (Check One) | | |
| <input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution | | |
| <p>Change the second sentence of R311.2 as follows: The egress door shall be <u>a side-hinged 3⁰ by 6⁸ door or larger</u>, and shall provide a minimum of ...</p> | | |
| REASON AND FISCAL IMPACT | | |
| <p>Reason: Having even one 36" door would be invaluable. Many furnishings will not go through a 32" wide door.</p> <p>This change makes the section clear that a 3⁰ by 6⁸ door is what is needed and keeps the IRC language as well.</p> <p>Fiscal impact: Minimal.</p> | | |
| REVIEW RECOMMENDATION | | |
| Approve | | |
| Disapprove | | |
| Approve as amended | | |
| Further Study | | |

Deleted: CHANGE "32 inches' " to "36 inches."¶

Formatted: Font color: Blue

Formatted: Font color: Blue

Formatted: Font color: Blue

Formatted: Font: 10 pt

Formatted: No underline

Formatted: Font: 10 pt